

## SUPPLEMENTAL/BID BULLETIN

## **ADDENDUM NO. 1**

Re-bidding for the Procurement for the Supply, Delivery and Installation of Airconditioning Equipment

This addendum dated December 20, 2016 is issued to clarify, modify or amend items in the Bid Document. This shall form part of the Bid Document.

ISSUES	CLARIFICATIONS/AMENDMENTS
Section VII Technical Specifications	> Section VII Technical Specifications
FEATURES, TECHNICAL SPECIFICATIONS OF 22 UNITS 1HP WINDOW TYPE AIR- CONDITIONING EQUIPMENT	FEATURES, TECHNICAL SPECIFICATIONS OF 22 UNITS 1HP WINDOW TYPE AIR- CONDITIONING EQUIPMENT
Technical Specifications:  Refrigerant R410A	Technical Specifications:  Refrigerant  R410A or R32
FEATURES, TECHNICAL SPECIFICATIONS OF 31 UNITS 1.5HP WINDOW TYPE AIR- CONDITIONING EQUIPMENT	FEATURES, TECHNICAL SPECIFICATIONS OF 31 UNITS 1.5HP WINDOW TYPE AIR- CONDITIONING EQUIPMENT
Technical Specifications:	Technical Specifications:
Refrigerant R410A	Refrigerant R410A or R32
FEATURES, TECHNICAL SPECIFICATIONS OF 57 UNITS 2HP WINDOW TYPE AIR- CONDITIONING EQUIPMENT  Technical Specifications: Refrigerant R410A	FEATURES, TECHNICAL SPECIFICATIONS OF 57 UNITS 2HP WINDOW TYPE AIR- CONDITIONING EQUIPMENT  Technical Specifications:  Refrigerant  R410A or R32

AND INSTALLATION OF 2 UNITS 1HP SPLIT TYPE **EQUIPMENT** 

FEATURES, TECHNICAL SPECIFICATIONS FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 2 UNITS 1HP SPLIT AIR-CONDITIONING TYPE AIR-CONDITIONING EQUIPMENT

Indoor unit		
Unit model	Inverter (using R41	type 0A)

Technical Specific	cations:	
Indoor unit		
Unit model	Inverter (using R4: R32)	type 10A or

Outdoor unit		
b. Refrigerant	R410A	

Outdoor unit	
b. Refrigerant	R410A or R32

FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 31 UNITS 1.5HP SPLIT TYPE AIR-CONDITIONING **EQUIPMENT** 

FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 31 UNITS 1.5HP SPLIT TYPE AIR-CONDITIONING **EQUIPMENT** 

Technical Specif	ications:	***************************************
Indoor unit		
Unit model	Inverter (using R41	type OA)

Technical Specif	ications:
Indoor unit	
Unit model	Inverter type (using R410A or R32)

Outdoor unit	
b Refrigerant	R410A

Outdoor unit	
b. Refrigerant	R410A or R32

FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 38 UNITS 2HP AIR-CONDITIONING SPLIT TYPE **EQUIPMENT** 

FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 38 UNITS 2HP SPLIT TYPE AIR-CONDITIONING **EQUIPMENT** 

Technical Specif Indoor unit	ications.	
Unit model	Inverter (using R41	type 0A)

Indoor unit		
Unit model	Inverter (using R41 R32)	type .0A or

Outdoor unit		
b. Refrigerant	R410A	

Outdoor unit	
b. Refrigerant	R410A or R32

FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 27 UNITS 2.5HP SPLIT TYPE AIR-CONDITIONING EQUIPMENT

Technical Specifications:
Indoor unit
Unit model Inverter type (using R410A)

Outdoor unit
b. Refrigerant R410A

FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 9 UNITS 3TR WALL MOUNTED/STANDING PACKAGE TYPE AIR-CONDITIONING EQUIPMENT

Technical Specifications:
Indoor unit
Unit model
Inverter type
(using R410A)

Outdoor unit
b. Refrigerant R410A

FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 27 UNITS 2.5HP SPLIT TYPE AIR-CONDITIONING EQUIPMENT

Technical Specifications:
Indoor unit
Unit model
Inverter type
(using R410A or R32)

Outdoor unit
b. Refrigerant R410A or R32

FEATURES, TECHNICAL SPECIFICATIONS AND INSTALLATION OF 9 UNITS 3TR WALL MOUNTED/STANDING PACKAGE TYPE AIR-CONDITIONING EQUIPMENT

Technical Specifications:
Indoor unit
Unit model
Inverter type (using R410A or R32)

Outdoor unit
b. Refrigerant R410A or R32

For guidance and information of all concerned.

ATTY. ERWIN T. MENDOZA
Vice-Chairperson, BOC-BAC