

A modernized and credible customs administration that uphoids good governance and is among the world's best

## BIDS AND AWARDS COMMITTEE

#### SUPPLEMENTAL/BID BULLETIN

#### ADDENDUM NO. 1

SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF STANDBY GENERATOR SETS WITH ACCESSORIES AND AUTOMATIC TRANSFER SWITCH (ATS) AT MICP, PORT OF CAGAYAN DE ORO, PORT OF DAVAO AND PORT OF SUBIC

This Addendum No. 1 dated 19 February 2025 is issued to clarify, modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents.

ISSUES	CLARIFICATION/AMENDMENTS
Section VII. Technical Specification	Section VII. Technical Specification
Lot 1 – Port of Subic (75KVA)	Lot 1 – Port of Subic (75KVA)
Installation, Testing and Commissioning	Installation, Testing and Commissioning
II. Electrical Works	II. Electrical Works
p. Testing and commissioning of new Generator and ATS with load;	p. Satisfactory rating of Load Bank Testing by the End-user;
Other Requirements	Other Requirements
c. Load Bank Test Result/Certification (issued by an independent or third-party company)	c. Undertaking by the bidder that a Load Bank Testing will be conducted in the presence of the members of the Technical Inspection and Acceptance Committee (TIAC) and that all related expenses shall be shouldered by the bidder
Lot 1 – Manila Internal Container Port (800KVA)	Lot 1 – Manila Internal Container Port (800KVA)
Installation, Testing and Commissioning	Installation, Testing and Commissioning

- II. Electrical Works
- s. Testing and commissioning of new Generator and ATS with load:

## Other Requirements

c. Load Bank Test Result/Certification (issued by an independent or third-party company)

## Lot 2 - Port of Davao (200KVA)

- II. Electrical Works
- p. Testing and commissioning of new Generator and ATS with load;

- II. Electrical Works
- s. Satisfactory rating of Load Bank Testing by the End-user;

## Other Requirements

c. Undertaking by the bidder that a Load Bank Testing will be conducted in the presence of the members of the Technical Inspection and Acceptance Committee (TIAC) and that all related expenses shall be shouldered by the bidder

## Lot 2 - Port of Davao (200KVA)

- II. Electrical Works
- p. Satisfactory rating of Load Bank Testing by the End-user;

#### Code and Standards

Notarized Undertaking that the bidder shall comply the following:

- a. PEC Philippine Electrical Code
- b. NFPA 110 Standard for Emergency and Standby Power System
- c. UL 1008 Standard for Automatic Transfer Switches

## Other Requirements

- a. Original Equipment Manufacturer (OEM) Certificate (Engine, Alternator and Controller)
- b. ISO Certificate (manufacturer)
- c. Undertaking by the bidder that a Load Bank Testing will conducted in the presence of the members of the Technical Inspection and Acceptance Committee (TIAC) and that all related expenses shall be shouldered by the bidder

# d. Operation and Maintenance Manual for Genset and Automatic Transfer Switch

e. Brochure of Generator Set and Automatic Transfer Switch

# Lot 2 – Port of Cagayan De Oro (Subport of Tagoloan) (200KVA)

- II Flectrical Works
- Testing and commissioning of new Generator and ATS with load;

# Other Requirements

c. Load Bank Test Result/Certification (issued by an independent or third-party company)

- Lot 2 Port of Cagayan De Oro (Subport of Tagoloan) (200KVA)
  - II. Electrical Works
  - o. Satisfactory rating of Load Bank Testing by the End-user;

# Other Requirements

c. Undertaking by the bidder that a Load Bank Testing will be conducted in the presence of the members of the Technical Inspection and Acceptance Committee (TIAC) and that all related expenses shall be shouldered by the bidder.

#### Reminders:

- Submission of bids will be on or before 03 March 2025, 9:30 AM.
- · Bids must be properly sealed and signed.
- Late submission will not be accepted.

For guidance and information of all concerned.

ATTY. ERWIN T. MEND Chairperson, BOC-BAC